

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC POOL AND BATHING PLACE
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 58-60-00969
Name of Facility: Southwood Block 4 Pool
Address: 4193 Timberline Boulevard
City, Zip: Venice 34293

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Pool > 25000 Gallons
Owner: Southwood Block 4 Homeowners Association Inc
Person In Charge: Reese, Mark Phone: (941) 408-8293
PIC Email:
Pool Operator: Royal Pool Management (CPC-1458129) Phone: (941) 915-3202

Inspection Information

Purpose: Routine
Inspection Date: 2/24/2022

Begin Time: 07:30 AM
End Time: 07:50 AM

Additional Information

22. Free Chlorine	3	VOLUME	26928
23. pH	7.8	POOL LOAD	20
24. Chlor. Stabilizer	0	FLOW RATE	100
33. Flowmeter	100	NIGHT SWIM	No
34. Thermometer	75	FILTER TYPE	CP

Items checked are not in compliance with Chapter 386 or 514, Florida Statutes, or Chapter 64E-9 or 64E-10, Florida Administrative Code. These violations must be corrected by the date indicated to avoid closure, administrative fines, or other legal actions. Florida Building Code (FBC) violations are reported to the local building official, and depending upon risk severity, the Department of Health may close the pool or rescind the operating permit.

Violation Markings

POOL AREA	X 17. Rules Posted	32. Vacuum Cleaner-FBC
1. Water Clarity/Algae Control	18. Certification	33. Flowmeter
2. Deck/Walkways	SANITARY FACILITIES	34. Thermometer
3. Tile/Pool Finish	19. Supplies 64E-10, FAC	35. Pressure/Vacuum Gauge
4. Depth Markers-FBC	20. Clean 64E-10, FAC	36. Equip. Room
5. Handrail/Ladder-FBC	WATER QUALITY	37. Cross Connection
6. Step Markings-FBC	21. Approved Test Kit	38. Gas Chlorine Eq.-FBC
7. Suction Outlets-514.0315(1)	22. Free Chlor./Brom.	39. Waste Water - FBC
8. Gutter Grates/Skimmer-FBC	23. pH	40. D.E. Separator-FBC
9. Lighting	24. Chlor. Stabilizer	41. Other Equipment
10. No Dive Markings-FBC	25. Spa Requirements-ORP	42. Equip. Change-FBC
11. Diving Board-FBC	EQUIPMENT ROOM	43. Approved Chemicals
12. Pool Cover	26. Wading Pool-Quick Dump	44. Maintenance Log
13. Pool Side Shower-FBC	27. Water Level/Control	45. Inspection Posted
POOL SAFETY	28. Disinfection Feeder/Generator	46. Safety-514.0315(2)
14. Life Hook(s) w/Pole	29. pH Feeder	47. Fences/Gates- FBC
15. Life Ring(s) w/Rope	30. Chem. Container Label-FBC	48. Other
16. Safety Line	31. Filter / Pump	49. Other

NOTE: It is unlawful to modify a public pool or its equipment without prior approval from the local building department and submitting an application to DOH.

Inspector Signature:

KAB

Client Signature:

email

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC POOL AND BATHING PLACE
INSPECTION REPORT



2 of 2

General Comments

No General Comments Available

Email Address(es): mark@keys-caldwell.com;
royalpoolmanagement@gmail.com;
mark@keys-caldwell.com

DOH Web Page For Pools: <http://www.floridahealth.gov/environmental-health/swimming-pools/index.html>

Violations Comments

Violation #17. Rules Posted

By January 1, 2022, all pools shall add: "POOL MAXIMUM DEPTH: __FEET," in 2-inch (51mm) letters to previously listed pool rules.
CODE REFERENCE: Rules Posted. 64E-9.004(4); 64E-9.008(6) & (13)(f). Signs shall be maintained legible from the pool deck as approved by the jurisdictional building department addressing: bathing load, pool operation time, no-diving, animals, glass, food/beverages, showering, swimming while ill, swallowing pool water, and additionally for spa pools: temperature, spa use time, minimum age, and vulnerable person caution.

Inspection Conducted By: Krist Bowman (85859)
Inspector Contact Number: Cell: (941) 893-0635
Print Client Name:
Date: 2/24/2022

Inspector Signature:

KAB

Client Signature:

email